

Attendance category	Boiler Type	Maximum power output and maximum design pressure	Supervision – Daily and weekly					Periodic checking, testing and maintenance																										
			By	When	Checking and testing to be performed			By	How	Period																								
					Clause 6.4.1	Clause 6.4.2	Clause 6.4.3																											
(a) Unattended operation	(i) Water-tube steam and hot-water boilers (excluding electrical elements)	(A) 10MW 6MPa	Trained person	24hr interval	Not applicable	Required appropriate to the boiler	Required appropriate to the boiler	Maintenance personnel as per this standard	As per Clause 6.4.4:	5 weeks maximum																								
		(B) 20MW 6MPa	Licensed boiler operator	4hr interval	Required																													
	(ii) Forced circulation toil steam boilers	10MW 10MPa	Trained person	24hr interval	Not applicable																													
	(iii) Fire-tube hot water boilers				5MW 2.5 MPa									Required																				
	(iv) Combined water-tube - fire-tube steam boilers	20MW 2.5MPa	Licensed boiler operator	4hr interval																														
	(v) All other types including fire-tube steam boilers	5MW 2.5 MPa		12hr interval																														
	(vi) Electrode or electric steam boilers (electric element fails on low- water)	No MW limit 2.5 MPa	Trained person	24hr interval															Not applicable					12 months maximum										
	(vii) Electric element steam boiler (electric element may not fail on low-water)	(A) 250kW 2.5 MPa																												5 weeks maximum				
(B) 6MW 2.5 MPa																																		
(viii) Boilers all types except for (vii) (A)	500kW 1.2MPa																																	3 months maximum
(b) Attended operation	All types		No limits	Licensed boiler operator		Refer to Clause 7.9 and AS/NZS 3788																												